

The Technical Specification for Replacement of Air Blowers 2 Nos and MBBR Media for Rectification & Recommissioning of 30 KLD STP Plant at Shilparamam, Madhapur.

S.No.	Particulars	Qty	Unit	Rate	Amount Rs
1	Supply of Air Blower along with Motor 40 CUM with 2 HP Motor make A1 Blower	02	Nos		
2	MBBR Media for Aeration tanks to increase the treatment capability	1.5	Cum		
3	Dismantling of existing blowers & blower lines and Erection, Installation & Commissioning of new Air Blowers 2Nos along with new blower lines and MBBR Media filling in the Aeration tanks etc., complete by Rectifying & Recommissioning the STP plant to draw output treated water as per the capacity of the plant.	1	Job		
	Total				
	GST @ 18%				
	TOTAL AMOUNT RS.				

- Note: 1. Any extra items if required can be added.
 2. The Firm must have minimum five years (5) experience in the installation & maintenance of STP plant. (The relevant copies may be enclosed for reference of experience).

The firm should submit the Sealed Quotation along with EMD amount Rs. 5,000/- through DD on or before 19/04/2025 up to 3.00 PM in favour of

SPECIAL OFFICER
 SHILPARAMAM
 HYDERABAD


 A.E(Electrical) 9/4/25